



# MASON INDUSTRIES, INC.



350 Rabro Drive • Hauppauge, NY 11788 • 631/348-0282 • FAX 631/348-0279  
2101 W. Crescent Ave., Suite D • Anaheim, CA 92801 • 714/535-2727 • FAX 714/535-5738  
Reply to - P.O. Box 410, Smithtown, NY 11787

Representatives in the U.S.A. & throughout the World




## NEOPRENE MOUNTINGS




## SPRING MOUNTS




## FLOATING FLOORS, CEILINGS & WALLS







## BASES



## SAFEFLEX CONNECTORS



## HANGERS



# SUBMITTAL DATA

PROJECT : AIRTRUNK DATA CENTRE WESTERN SYDNEY

ARCHITECT :

ENGINEER :

CONTRACTOR :

P.O. NUMBER : NSW

COMMENTS :

DATE : 03/08/18

M.I. No. : 634928



**MASON INDUSTRIES, Inc.**

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON-MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507841

**DRAWING  
 CERTIFICATION  
 INDEX**

EQUIPMENT TAG(S)	MANUFACTURER	ISOLATION		SEISMIC MATERIAL	MASON IND. DWG. NO.
		TYPE	DEFL.		
PIPING (T1)	N/A			SCB, SCBH, SRC, SAS	F-507061 ~ 061C
ROOF PIPING	N/A			SAS	F-506062 ~ 062C, F-506842~ 843C
PIPE BRACING LAYOUT					E-62940
PIPE BRACING DETAIL					E-62657
Ref. Dwg.(s)					
				SCB	S-102
				SCBH	S-108
				SRC	S-104
				CCB	S-109
				SAS	S-106

Material to be provided by Mason Industries has been selected and designed to withstand seismic and wind loadings as required per building code and job specifications.

I hereby certify that these documents listed above were prepared or approved by me, and I am a duly licensed professional engineer under the laws of the state of the project.

No other responsibility is taken or implied by this engineer.




# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507061

## SEISMIC DETAIL SUSPENDED PIPING

TAG(S) 140 mm CW (PVC) PIPING @ 13.5 #/FT.  
 40 FT. [12 m] MAX. NO. REQ'D. N/A  
 UNIT N/A






\* MASON SRC SEISMIC ROD CLAMPS ARE REQUIRED FOR ROD LENGTH "L" GREATER THAN 60" [1525 mm].

ELEVATION VIEW OF PIPING

SINGLE EXPANSION ANCHOR TO MINIMUM 3000 PSI CONCRETE

### ALTERNATE ATTACHMENT DETAILS





# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507061A

**STATIC  
 ANALYSIS**  
 SUSPENDED  
 PIPING

TAG(S) 140 mm CW (PVC) PIPING @ 13.5 #/FT.  
 40 FT. [12 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

## SYSTEM INFORMATION

- Wc, Equipment weight = 540 lbs.
- Fp, Horizontal force established by earthquake = 270 lbs.
- Fpv, Vertical force established by earthquake = 135 lbs.
- Fca, Force established in cable due to earthquake = 382 lbs.
- t, Tension in one cable anchor to structure = 373 lbs.
- v, Shear in one cable anchor to structure = 270 lbs.

## AUSTRALIAN STANDARD AS 1170.4-2007 SEC. 8.3

$a_{floor}$ : Effective floor acceleration =  $k_p Z C_n(0) = 0.158$

$k_p$ : Probability Factor = 1.80

Z: Hazard Factor = 0.08

$C_n(0)$ : Bracketed value of the spectral  
 shape for the period of 0 sec. = 1.1 ( $D_e$ )

$a_x$ : Height amplification factor at height  $h_x = (1 + k_c h_x) = 3.0$

$h_x$ : Height at which component is attached = 75 m.

$h_n$ : Total height of structure = 75 m.

$k_c$ :  $2/h_n$  for  $h_n \geq 12$  m.  
 : 0.17 for  $h_n < 12$  m.

$I_c$ : Component importance factor = 1.5

$a_c$ : Component amplification factor = 1.0

$R_c$ : Component ductility factor = 1.0


$$F_p = F_c = a_{floor} a_x [I_c a_c / R_c] W_c \leq 0.50 W_c$$

$$= 0.50 \times W_c$$

$$= 270 \text{ lbs.}$$

$$F_{pv} = F_{cv} = 0.50 \times F_c$$

$$= 135 \text{ lbs.}$$



10/2010

DWN: IB

CHKD:

DATE: 02/05/18

DWG. NO.

F-507061A



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507061B

## STATIC ANALYSIS SUSPENDED PIPING

TAG(S) 140 mm CW (PVC) PIPING @ 13.5 #/FT.  
 40 FT. [12 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

### Compressive Force established in one hanger rod due to earthquake

### References

$$W_{supp} = W_p/ft. \times 10 \text{ ft.} = 135 \text{ lbs.}$$

$$F_{pc} = F_p \times \tan 45^\circ = 270 \text{ lbs.}$$

$$F_c = F_{pc} - W_{supp} + F_{pv}$$

Therefore,  $F_c = 270 \text{ lbs.}$

NOTE: If  $F_c < 0$ , assume  $F_c = 0$ .

#### Allowable Compressive Force established in one hanger rod

$$\frac{KI}{r} = \frac{(1.0) \times (60 \text{ in.})}{0.156 \text{ in.}} = 385$$

$$F_a = \frac{12 \pi^2 E}{23 (KI/r)^2} = 1007 \text{ lbs./in.}^2$$

$$E = 29 \times 10^6 \text{ lbs./in.}^2$$

$$F_{call} = F_a \times A_k \times 1.33^*$$


$$A_k = 0.202 \text{ in.}^2$$

Therefore,  $F_{call} = 271 \text{ lbs.}$

Since  $F_{call}$  is greater than or equal to  $F_c$  the hanger rod is adequate unbraced up to a length of 60 in.

Manual of  
STEEL  
CONSTRUCTION  
9TH EDITION  
5-42 Sec. E2

\*5-30 Sec. A5



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507061C

## STATIC ANALYSIS SUSPENDED PIPING

TAG(S) 140 mm CW (PVC) PIPING @ 13.5 #/FT.  
 40 FT. [12 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

### Force established in cable assembly due to earthquake

$$F_{ca} = F_p / \cos 45^\circ$$

$$\text{Therefore, } F_{ca} = 382 \text{ lbs.}$$

Therefore, a 1/8" SCBH cable assembly rated at 975 lbs.  
 (Based on a 2:1 safety factor) is adequate.

### Force transmitted to anchor

$$v = F_{ca} \times \cos 45^\circ$$

$$\text{Therefore, } v = 270 \text{ lbs.}$$

$$t = F_{ca} \times \sin 45^\circ \times 1.38^*$$

$$\text{Therefore, } t = 373 \text{ lbs.}$$

\*Increase due to prying effect on anchor bolt.

The allowable loads for anchors subjected to combined shear and tension forces are determined by the ratio of actual shear to allowable shear plus the ratio of the actual tension to the allowable tension not to exceed 1.2

The above can be satisfied by the expression:

$$\frac{v}{V_{allow.}} + \frac{t}{T_{allow.}} \leq 1.2$$

Using SAS-1/2 with 2-3/4" minimum embedment into 3000 psi concrete we get:

$$V_{allow.} = 1155 \text{ lbs. and } T_{allow.} = 1070 \text{ lbs.}$$

Inserting these values we have:

$$\frac{270}{1155} + \frac{373}{1070} = 0.59 \leq 1.2$$

Therefore the above anchors are adequate.

"In order to insure the integrity of the seismic restraint system, these calculations are based on using Mason style SAS anchor bolts. If other bolts are furnished, these calculations may require revision by the new anchor bolt manufacturer. This manufacturer must furnish the appropriate anchors based on the shear and tension forces calculated."

### References

Reference  
Dwg. S-108

Reference  
Dwg. S-106

ICC-ES  
Report  
ESR-1771/3037




# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507062


**SEISMIC  
 DETAIL  
 OUTDOOR  
 APPLICATION**

TAG(S)	4" (100 mm) CW H/L ROOF PIPING @ 36.0 #/FT. TOTAL	NO. REQ'D.	N/A
UNIT	12 FT. [3.7 m] MAX.		
	N/A		



\*\*APPROXIMATE

ELEVATION VIEW OF SYSTEM



PLAN VIEW OF SYSTEM



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www. Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507062A

**STATIC  
 ANALYSIS**  
 OUTDOOR  
 APPLICATION

TAG(S) 4" (100 mm) CW H/L ROOF PIPING @ 36.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

## SYSTEM INFORMATION

- Wc, Equipment weight = 440 lbs.
- Fp, Horizontal force established by earthquake = 128 lbs.
- Fpv, Vertical force established by earthquake = 64 lbs.
- Fw, Horizontal force established by wind = 274 lbs.
- Hc.g., Center of gravity in vertical direction = 8.0 in.
- d, Depth of system = 5.75 in.
- Hb, Height between bolts of the system = 16.0 in.
- Nb, Total number of bolts = 2

## AUSTRALIAN STANDARD AS 1170.4-2007 SEC. 8.3

$a_{floor}$ : Effective floor acceleration =  $k_p Z C_n(0) = 0.158$

$k_p$ : Probability Factor = 1.80

Z: Hazard Factor = 0.08

$C_n(0)$ : Bracketed value of the spectral  
 shape for the period of 0 sec. = 1.1 ( $D_e$ )

$a_x$ : Height amplification factor at height  $h_x = (1 + k_c h_x) = 3.0$

$h_x$ : Height at which component is attached = 75 m.

$h_n$ : Total height of structure = 75 m.

$k_c$ :  $2/h_n$  for  $h_n \geq 12$  m.

: 0.17 for  $h_n < 12$  m.

$I_c$ : Component importance factor = 1.5

$a_c$ : Component amplification factor = 1.0

$R_c$ : Component ductility factor = 2.5

$$F_p = F_c = a_{floor} a_x [I_c a_c / R_c] W_c \leq 0.50 W_c$$

$$= 0.29 \times W_c$$

$$= 128 \text{ lbs.}$$

$$F_{pv} = F_{cv} = 0.50 \times F_c$$

$$= 64 \text{ lbs.}$$

10/2010

DWN: IB

CHKD:

DATE: 02/05/18

DWG. NO.

F-507062A





# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507062B

**STATIC  
 ANALYSIS**  
 OUTDOOR  
 APPLICATION

TAG(S) 4" (100 mm) CW H/L ROOF PIPING @ 36.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

## AUSTRALIAN/NEW ZEALAND STANDARD AS/NZS 1170.2 STRUCTURAL DESIGN ACTIONS PART 2: WIND ACTIONS

### References

$$p_z = \text{Design Wind Pressure} = (0.5 \times \rho_{\text{air}}) \times [V_{\text{des}, \theta}]^2 \times C_{\text{fig}} \times C_{\text{dyn}} \quad (\text{Equation 2.4-1})$$

$\rho_{\text{air}} = \text{Density of air} = 1.2 \text{ kg/m}^2 \quad (\text{Sec. 2.4.1 p.12})$   
 $V_{\text{des}, \theta} = V_R \times M_d \times (M_{z, \text{cat}} \times M_s \times M_t) = 50.4 \text{ m/s} \quad (\text{Sec. 2.3 p.9})$   
 $V_R = \text{Regional wind speed} = 45.0 \text{ m/s} \quad (\text{Region A2}) \quad (\text{Table 3.1 p.14})$   
 $M_d = \text{Wind direction multiplier} = 1.0 \quad (\text{Table 3.2 p.15})$   
 $M_{z, \text{cat}} = \text{Terrain/Height multiplier} = 1.12 \quad (z = 75 \text{ m, Cat. 3}) \quad (\text{Table 4.1 (A) p.19})$   
 $M_s = \text{Shielding multiplier} = 1.0 \quad (\text{Sec. 4.3.1 4.3 p.21})$   
 $M_t = \text{Topographic multiplier} = 1.0 \quad (\text{Sec. 4.4.1 p.22})$   
 $C_{\text{fig}} = \text{Aerodynamic shape factor} = 0.80 \quad (\text{Sec. 5.2 p.27})$   
 $C_{\text{dyn}} = \text{Dynamic Response factor} = 1.0 \quad (\text{Sec. 6.1 p.39})$

$$= 1220 \text{ Pa}$$

$$A_z = \text{Projected area normal to wind} = 1.0 \text{ m}^2$$

$$F_w = p_z \times A_z \quad (\text{Equation 2.5-1})$$

$$= 1220 \text{ N [274 lbs.]}$$

Since the earthquake load demand is less than the wind load demand,  
 the wind load demand will be used for determining support forces.



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507062C

**STATIC  
 ANALYSIS  
 OUTDOOR  
 APPLICATION**

TAG(S) 4" (100 mm) CW H/L ROOF PIPING @ 36.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

## Actual Tension on one anchor bolt, T

$$T = \{F_w \times H_c.g. + W_c \times d\} / H_b$$

$$\text{Therefore, } T = 295 \text{ lbs.}$$

NOTE: If  $t < 0$ , assume  $t = 0$ .

## Actual Shear on one anchor bolt, V

$$V_1 = W_c / N_b = 220 \text{ lbs.} \quad V_2 = F_w / N_b = 137 \text{ lbs.}$$

$$V = \sqrt{V_1^2 + V_2^2}$$

$$\text{Therefore, } V = 259 \text{ lbs.}$$

## References

Reference  
 Dwg. S-106

ICC-ES  
 Report  
 ESR-1771/3037

The allowable loads for anchors subjected to combined shear and tension forces are determined by the ratio of actual shear to allowable shear plus the ratio of the actual tension to the allowable tension not to exceed 1.2

The above can be satisfied by the expression:

$$\frac{V}{V_{allow.}} + \frac{T}{T_{allow.}} \leq 1.2$$

Using SAS-3/8 with 1 7/8" minimum embedment into 3000 psi lightweight concrete we get:

$$V_{allow.} = 630 \text{ lbs. and } T_{allow.} = 485 \text{ lbs.}$$

Inserting these values we have:

$$\frac{259}{630} + \frac{295}{485} = 1.02 \leq 1.2$$

Therefore the above anchors are adequate.

"In order to insure the integrity of the seismic restraint system, these calculations are based on using Mason style SAS anchor bolts. If other bolts are furnished, these calculations may require revision by the new anchor bolt manufacturer. This manufacturer must furnish the appropriate anchors based on the shear and tension forces calculated."




# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507842


**SEISMIC  
 DETAIL  
 OUTDOOR  
 APPLICATION**

TAG(S) 4" (110 mm) CW ROOF PIPING @ 18.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
 UNIT N/A



\*\*APPROXIMATE

ELEVATION VIEW OF SYSTEM



PLAN VIEW OF SYSTEM



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507843A

**STATIC  
 ANALYSIS**  
 OUTDOOR  
 APPLICATION


TAG(S) 4" (110 mm) CW ROOF PIPING @ 18.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

## SYSTEM INFORMATION

- Wc, Equipment weight = 220 lbs.
- Fp, Horizontal force established by earthquake = 64 lbs.
- Fpv, Vertical force established by earthquake = 32 lbs.
- Fw, Horizontal force established by wind = 137 lbs.
- Hc.g., Center of gravity in vertical direction = 5.0 in.
- d, Depth of system = 6.0 in.
- Hb, Height between bolts of the system = 10.0 in.
- Nb, Total number of bolts = 2

## AUSTRALIAN STANDARD AS 1170.4-2007 SEC. 8.3

- a<sub>floor</sub>: Effective floor acceleration =  $k_p Z C_n(0) = 0.158$ 
  - k<sub>p</sub>: Probability Factor = 1.80
  - Z: Hazard Factor = 0.08
- C<sub>n</sub>(0): Bracketed value of the spectral shape for the period of 0 sec. = 1.1 (D<sub>e</sub>)
- a<sub>x</sub>: Height amplification factor at height h<sub>x</sub> =  $(1 + k_p h_x) = 3.0$ 
  - h<sub>x</sub>: Height at which component is attached = 75 m.
  - h<sub>n</sub>: Total height of structure = 75 m.
- k<sub>c</sub>:  $2/h_n$  for h<sub>n</sub> ≥ 12 m.  
: 0.17 for h<sub>n</sub> < 12 m.
- I<sub>c</sub>: Component importance factor = 1.5
- a<sub>c</sub>: Component amplification factor = 1.0
- R<sub>c</sub>: Component ductility factor = 2.5
- Fp = Fc = a<sub>floor</sub> a<sub>x</sub> [I<sub>c</sub> a<sub>c</sub> / R<sub>c</sub>] Wc ≤ 0.50 Wc
  - = 0.29 x Wc
  - = 64 lbs.
- Fpv = Fcv = 0.50 x Fc
  - = 32 lbs.



**MASON INDUSTRIES, Inc.**

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507843B

**STATIC  
 ANALYSIS**  
 OUTDOOR  
 APPLICATION

TAG(S) 4" (110 mm) CW ROOF PIPING @ 18.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
 UNIT N/A

**AUSTRALIAN/NEW ZEALAND STANDARD AS/NZS 1170.2  
 STRUCTURAL DESIGN ACTIONS PART 2: WIND ACTIONS**

**References**

$p_z = \text{Design Wind Pressure} = (0.5 \times \rho_{\text{air}}) \times [V_{\text{des}, \theta}]^2 \times C_{\text{fig}} \times C_{\text{dyn}}$  (Equation 2.4-1)

$\rho_{\text{air}} = \text{Density of air} = 1.2 \text{ kg/m}^2$  (Sec. 2.4.1 p.12)

$V_{\text{des}, \theta} = V_R \times M_d \times (M_{z, \text{cat}} \times M_s \times M_t) = 50.4 \text{ m/s}$  (Sec. 2.3 p.9)

$V_R = \text{Regional wind speed} = 45.0 \text{ m/s}$  (Region A2) (Table 3.1 p.14)

$M_d = \text{Wind direction multiplier} = 1.0$  (Table 3.2 p.15)

$M_{z, \text{cat}} = \text{Terrain/Height multiplier} = 1.12$  ( $z = 75 \text{ m}$ , Cat. 3) (Table 4.1 (A) p.19)

$M_s = \text{Shielding multiplier} = 1.0$  (Sec. 4.3.1 4.3 p.21)

$M_t = \text{Topographic multiplier} = 1.0$  (Sec. 4.4.1 p.22)

$C_{\text{fig}} = \text{Aerodynamic shape factor} = 0.80$  (Sec. 5.2 p.27)

$C_{\text{dyn}} = \text{Dynamic Response factor} = 1.0$  (Sec. 6.1 p.39)

= 1220 Pa

$A_z = \text{Projected area normal to wind} = 0.5 \text{ m}^2$

$F_w = p_z \times A_z$  (Equation 2.5-1)

= 610 N [137 lbs.]

Since the earthquake load demand is less than the wind load demand,  
 the wind load demand will be used for determining support forces.



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. F-507843C

**STATIC  
 ANALYSIS**  
 OUTDOOR  
 APPLICATION

**TAG(S)** 4" (110 mm) CW ROOF PIPING @ 18.0 #/FT. TOTAL  
 12 FT. [3.7 m] MAX. NO. REQ'D. N/A  
**UNIT** N/A

## Actual Tension on one anchor bolt, T

$$T = \{F_w \times H_c.g. + W_c \times d\} / H_b$$

Therefore, t = 201 lbs.

NOTE: If t < 0, assume t = 0.

## Actual Shear on one anchor bolt, V

$$V_1 = W_c / N_b = 110 \text{ lbs.} \quad V_2 = F_w / N_b = 69 \text{ lbs.}$$

$$v = \sqrt{V_1^2 + V_2^2}$$

Therefore, v = 130 lbs.

## References

Reference  
 Dwg. S-106

ICC-ES  
 Report  
 ESR-1771/3037

The allowable loads for anchors subjected to combined shear and tension forces are determined by the ratio of actual shear to allowable shear plus the ratio of the actual tension to the allowable tension not to exceed 1.2

The above can be satisfied by the expression:

$$\frac{v}{V_{allow.}} + \frac{t}{T_{allow.}} \leq 1.2$$

Using SAS-3/8 with 1 7/8" minimum embedment into 3000 psi lightweight concrete we get:

$$V_{allow.} = 630 \text{ lbs. and } T_{allow.} = 485 \text{ lbs.}$$

Inserting these values we have:

$$\frac{130}{630} + \frac{201}{485} = 0.62 \leq 1.2$$

Therefore the above anchors are adequate.

"In order to insure the integrity of the seismic restraint system, these calculations are based on using Mason style SAS anchor bolts. If other bolts are furnished, these calculations may require revision by the new anchor bolt manufacturer. This manufacturer must furnish the appropriate anchors based on the shear and tension forces calculated."




# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. S-102

# SCB


SEISMIC CABLE  
 BRACE ANCHOR  
 & ASSEMBLY




SCB-1,2,3 & 4

TYPE SCB DIMENSION (in mm)

Size	A	B	C	D	E	F	G	H
SCB-0	15/16 33	1 1/2 38	3/4 19	15/16 24	1 3/4 44	- -	7/16 11	1/2 13
SCB-1	13/8 35	2 51	1 25	15/16 24	3 3/8 86	1 1/2 38	9/16 14	1/2 13
SCB-2	15/8 41	2 3/4 70	1 3/8 35	1 3/16 30	4 3/8 111	1 3/4 44	1 1/16 17	5/8 16
SCB-3	2 51	3 1/2 89	1 3/4 44	1 7/16 37	4 3/4 121	2 51	13/16 21	3/4 19
SCB-3-2B	2 51	4 3/4 121	1 25	1 7/16 37	4 3/4 121	2 51	13/16 21	3/4 19
SCB-4	3 1/8 79	5 127	2 1/2 64	1 15/16 49	5 3/4 146	2 1/4 57	1 5/16 33	1 25



SCB-3-2B



SCB-0

Ratings are from test data and calculations used to obtain California OSHPD Preapproval Number OPA-0349.

Testing was supervised and certified by an independent engineer registered in the State of California.

Ratings are based on attachment to steel.

Preferred installation angle is 45°. Maximum variation ±15°.

NOTE: Not to be used as a vertical hanger for equipment, ductwork or piping. To be used as a seismic restraint only.

## APPROVED

California Office of Statewide Health Planning and Development

FIXED EQUIPMENT ANCHORAGE  
 OPA-0349 December 22, 2006



*Anthony R. Pike*

Anthony R. Pike (916) 654-3362

### TYPE SCB ASSEMBLY RATINGS AS CONTROLLED BY CABLE BREAKING STRENGTH

Size	Cable Diameter		OSHPD Max. Ratings			Torque on Bolts		
	in	mm	lbs	kN	kg	ft-lbs	N-m	kg-m
SCB-0	1/16*	1.6	235	1.0	106	30	41	4.2
SCB-0	3/32*	2.4	460	2.1	208	30	41	4.2
SCB-0	3/32	2.4	500	2.2	227	30	41	4.2
SCB-1	1/8	3	975	4.3	442	25	34	3.5
SCB-2	3/16	5	2050	9.1	930	45	61	6.2
SCB-3 & -3-2B	1/4	6	3150	14.0	1429	55	75	7.6
SCB-4	3/8	10	6875	30.5	3119	200	271	27.6

\* 7 x 7 STRAND CORE

REF. DWG. S-102





# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products  
 350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. S-108

# SCBH

SEISMIC CABLE  
 BRACE HOOK  
 ANCHOR &  
 ASSEMBLY



Ratings for SCBH-1 thru -3 are from test data and calculations used to obtain California OSHPD Preapproval Number OPA-0349. Testing was supervised and certified by an independent engineer registered in the State of California. Ratings are based on attachment to steel. SCBH assemblies will fit rod sizes as tabulated. Preferred installation angle is 45°. Maximum variation is ± 15°.

### TYPE SCBH DIMENSIONS (inches mm)

Size	For use with Rod Sizes	A	B	C	D	E	F	G	H
SCBH-0	3/8 10	1 3/8 35	2 1/16 52	1 1/16 17	15/16 24	1 3/4 44	-- --	3/8 10	1/2 13
SCBH-1	1/2, 5/8 13, 16	1 7/8 48	2 3/8 60	1 25	1 25	3 3/8 86	1 1/2 38	5/8 16	1/2 13
SCBH-2	3/4, 7/8 19, 22	2 7/8 73	3 3/4 95	1 3/8 35	1 3/16 30	4 3/8 111	1 3/4 44	7/8 22	5/8 16
SCBH-3	1, 1 1/8 25, 29	3 1/2 89	4 3/4 121	1 3/4 44	1 7/16 37	4 3/4 121	2 51	1 1/8 29	3/4 19

## APPROVED

California Office of Statewide Health Planning and Development

FIXED EQUIPMENT ANCHORAGE

OPA-0349 AUGUST 5, 2002



*Bill Staehlin*

Bill Staehlin (916) 654-3362

### TYPE SCBH ASSEMBLY RATINGS AS CONTROLLED BY CABLE BREAKING STRENGTH

Size	Cable Diameter	OSHPD Max. Ratings			Torque on Bolts			
		in	mm	lbs	kN	kg	ft-lbs	N-m
SCBH-0	1/16*	1.6	235	1.0	106	30	41	4.2
SCBH-0	3/32*	2.4	460	2.1	208	30	41	4.2
SCBH-0	3/32	2.4	500	2.2	227	30	41	4.2
SCBH-1	1/8	3	975	4.3	442	25	34	3.5
SCBH-2	3/16	5	2050	9.1	930	45	61	6.2
SCBH-3	1/4	6	3150	14.0	1429	55	75	7.6

\* 7 x 7 STRAND CORE

REF. DWG. S-108





# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products

350 Rabro Drive 2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788 Anaheim, CA 92801  
 631/348-0282 714/535-2727  
 FAX 631/348-0279 FAX 714/535-5738  
 Info@Mason-Ind.com Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE  
 CUSTOMER MASON MERCER AUSTRALIA  
 CUSTOMER P.O. NSW  
 MASON M.I. 634928  
 DWG. NO. S-104

**SRC**  
 Seismic  
 Rod  
 Clamps

### TYPE SRC DIMENSIONS - Inches (mm)

Size	A	B	C	D Acceptable Rod Size
SRC-1	1 3/8 (35)	1/2 x 1 3/4 Long (13 x 44 Long)	1 x 1 x 1/8 (25 x 25 x 3)	1/4 to 5/8 (6 to 16)
SRC-1 1/2	1 9/16 (40)	5/8 x 2 Long (16 x 51 Long)	1 1/2 x 1 1/2 x 1/4 (38 x 38 x 6)	1/2 to 1 (13 to 25)
SRC-2	1 3/4 (44)	5/8 x 3 Long (16 x 76 Long)	2 x 2 x 1/4 (51 x 51 x 6)	7/8 to 1 1/4 (22 to 32)

**APPROVED**

California Office of Statewide  
 Health Planning and Development

**FIXED EQUIPMENT ANCHORAGE**



**OPA-0349 AUGUST 5, 2002**



*Bill Staehlin*  
 Bill Staehlin (916) 654-3362

### TYPE SRC WITH STEEL ANGLE ASSEMBLY RATINGS - inches (mm)

Rod Size in (mm)	Maximum Compr. Force lbs (kN)	Steel Angle Stiffener		Maximum SRC Spacing in (mm)
		Min. Size in (mm)	Max. Length in (mm)	
1/4 (6)	75 (0.3)	1 x 1 x 1/8 (25 x 25 x 3)	96 (2438)	14 (356)
3/8 (10)	425 (1.9)	1 x 1 x 1/8 (25 x 25 x 3)	96 (2438)	22 (559)
1/2 (13)	1275 (5.6)	1 x 1 x 1/8 (25 x 25 x 3)	96 (2438)	31 (787)
	1200 (5.3)	1 1/2 x 1 1/2 x 1/4 (38 x 38 x 6)	120 (3048)	31 (787)
5/8 (16)	1475 (6.5)	1 x 1 x 1/8 (25 x 25 x 3)	96 (2438)	39 (991)
	1325 (5.9)	1 1/2 x 1 1/2 x 1/4 (38 x 38 x 6)	120 (3048)	39 (991)
3/4 (19)	2500 (11.1)	1 1/2 x 1 1/2 x 1/4 (38 x 38 x 6)	144 (3658)	48 (1212)
7/8 (22)	4600 (20.4)	1 1/2 x 1 1/2 x 1/4 (38 x 38 x 6)	132 (3353)	56 (1422)
	4400 (19.5)	2 x 2 x 1/4 (51 x 51 x 6)	144 (3658)	56 (1422)
1 (25)	5800 (25.8)	1 1/2 x 1 1/2 x 1/4 (38 x 38 x 6)	132 (3353)	65 (1651)
	6900 (30.7)	2 x 2 x 1/4 (51 x 51 x 6)	144 (3658)	65 (1651)
1 1/8 (29)	9600 (42.7)	2 x 2 x 1/4 (51 x 51 x 6)	144 (3658)	73 (1854)
1 1/4 (32)	12000 (53.4)	2 x 2 x 1/4 (51 x 51 x 6)	144 (3658)	82 (2083)



REF. DWG. S-104



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products

350 Rabro Drive      2101 W. Crescent Ave., Suite D  
 Hauppauge, NY 11788      Anaheim, CA 92801  
 631/348-0282      714/535-2727  
 FAX 631/348-0279      FAX 714/535-5738  
 Info@Mason-Ind.com      Info@MasonAnaheim.com  
 www.Mason-Ind.com

JOB NAME AIRTRUNK DATA CENTRE



CUSTOMER MASON MERCER AUSTRALIA

CUSTOMER P.O. NSW

MASON M.I. 634928


DWG. NO. S-109

**CCB**  
 CLEVIS  
 CROSS BRACE



**TYPE CCB DIMENSIONS (inches)**

Size	L	H	A
CCB-1 1/2	1 7/8	1	15/16
CCB-2	2 3/8	1	1 3/16
CCB-2 1/2	2 7/8	1 1/8	1 7/16
CCB-3	3 1/2	1 1/8	3/4
CCB-4	4 1/2	1 1/8	1
CCB-5	5 9/16	1 5/16	1
CCB-6	6 5/8	1 5/16	1 1/2
CCB-8	8 5/8	1 7/16	2
CCB-10	10 3/4	1 9/16	2 1/2
CCB-12	12 3/4	1 9/16	3
CCB-14	14	1 11/16	3 1/2
CCB-16	16	1 7/8	4
CCB-18	18	2	4 1/2
CCB-20	20	2 1/2	5
CCB-24	24	2 1/2	6
CCB-30	30	2 1/2	7 1/2



**APPROVED**

California Office of Statewide  
 Health Planning and Development

**FIXED EQUIPMENT ANCHORAGE**  
**OPA-0349      AUGUST 5, 2002**



*Bill Staehlin*  
 Bill Staehlin (916) 654-3362

REF. DWG. S-109



# MASON INDUSTRIES, Inc.

Manufacturers of Vibration Control Products

350 Rabro Drive  
Hauppauge, NY 11788  
631/348-0282  
FAX 631/348-0279

2101 W. Crescent Ave., Suite D  
Anaheim, CA 92801  
714/535-2727  
FAX 714/535-5738  
Info@Mason-Ind.com • www.Mason-Ind.com


JOB NAME AIRTRUNK DATA CENTRE  
CUSTOMER MASON MERCER AUSTRALIA  
CUSTOMER P.O. NSW  
MASON M. 634928  
DWG No. S-106

## SAS & SASE

ZINC PLATED CARBON  
STEEL SEISMIC  
ANCHOR STUD WITH  
NUT & WASHER  
(Standard & Extended  
Length)

### TYPE SAS STANDARD LENGTH ANCHOR STUD RATINGS BASED ON ALLOWABLE STRESS DESIGN (ASD)\* installed into 2500 psi (17.2 Mpa) Normal Weight or Sand-Lightweight Concrete

Type and Size	Embedment Depth (Nominal) (in) (mm)		Normal Weight Concrete		Lightweight Concrete					
			Tension† (lbs) (kg)	Shear (lbs) (kg)	Tension† (lbs) (kg)	Shear (lbs) (kg)				
SAS-3/8	17/8	48	445	200	650	295	360	165	390	175
SAS-1/2	23/4	70	980	445	1055	480	590	270	635	290
SAS-5/8	33/8	86	1325	600	2845	1290	795	360	1710	775
SAS-3/4	41/8	105	1520	690	3870	1755	915	415	2325	1055
SAS-1	51/4	133	2220	1005	5960	2705	1335	605	3575	1620



### TYPE SASE EXTENDED LENGTH ANCHOR STUD RATINGS BASED ON ALLOWABLE STRESS DESIGN (ASD)\* installed into 2500 psi (17.2 Mpa) Normal Weight or Sand-Lightweight Concrete

Type and Size	Embedment Depth (Nominal) (in) (mm)		Normal Weight Concrete		Lightweight Concrete					
			Tension† (lbs) (kg)	Shear (lbs) (kg)	Tension† (lbs) (kg)	Shear (lbs) (kg)				
SASE-3/8	27/8	73	950	430	820	390	690	315	820	370
SASE-1/2	37/8	98	1275	580	2960	1340	1080	490	2325	1055
SASE-5/8	51/8	130	2355	1070	4520	2050	1660	755	3580	1625
SASE-3/4	53/4	146	2740	1245	6980	3165	1645	745	4190	1900

### TYPE SAS & SASE ANCHOR STUD RATINGS BASED ON ALLOWABLE STRESS DESIGN (ASD)\* installed in the Soffit of 3000 psi (20.7 Mpa) Normal Weight or Sand-Lightweight Concrete-filled Profile Steel Deck Assemblies (minimum 20 gauge 3" 76mm profile). Anchors must be installed in either the lower or upper flutes of the profile deck no more than 1" 25mm from flute centerline.

Type and Size	Embedment Depth (Nominal) (in) (mm)		Tension†		Shear	
			(lbs) (kg)	(lbs) (kg)	(lbs) (kg)	(lbs) (kg)
SAS-3/8	17/8	48	430	195	725	330
SASE-3/8	33/8	86	760	345	1590	720
SAS-1/2	23/4	70	695	315	970	440
SASE-1/2	41/2	114	930	420	2085	945
SAS-5/8	33/8	86	890	405	1200	545
SASE-5/8	55/8	143	1700	770	3185	1445

For combined allowable stress design tension and shear forces on anchors, use the following equation:

$$\frac{T_{\text{Applied}}}{T_{\text{Allowable (ASD)}}} + \frac{V_{\text{Applied}}}{V_{\text{Allowable (ASD)}}} \leq 1.2$$

### TYPE SAS & SASE ANCHOR STUD DIMENSIONS

Type and Size	A		B		Maximum Tightening Torque	
	(in)	(mm)	(in)	(mm)	(Ft-lbs)	(N-m)
SAS-3/8	31/2	89	3/8	10	30	41
SAS-1/2	43/4	121	1/2	13	60	81
SAS-5/8	5	127	5/8	16	90	122
SAS-3/4	61/4	159	3/4	19	150	203
SAS-1	7	178	1	25	230	312
SASE-3/8	5	127	3/8	10	30	41
SASE-1/2	51/2	140	1/2	13	60	81
SASE-5/8	7	178	5/8	16	90	122
SASE-3/4	81/2	216	3/4	19	150	203

Anchors have the following Code Reports:

- ICC-ES-ESR-3037 and City of Los Angeles RR25891 for cracked & uncracked concrete
- Florida Statewide Product Approval FL15731
- IAPMO ES ER 240 & City of Los Angeles RR25936 for CMU Walls
- Underwriter Laboratories file EX3605
- Factory Mutual #3043442

\* These values are applicable when the anchors are installed with periodic special inspection as set forth in Section 1701.5.2 of the UBC, Section 1704.13 of the 2006/2003 IBC or Section 1704.15 of the 2009 IBC.

† The Tension values may be increased for greater compressive strength, up to 8000 psi (55.2 MPa), by multiplying the value by  $(F'_c/2500)^{0.5}$ , where  $F'_c$  is the specified strength of concrete in psi.  
For example: SAS-1/2 in 4000 psi normal weight concrete

$$T = \left(\frac{4000}{2500}\right)^{0.5} \times 980 \text{ lbs} = 1240 \text{ lbs}$$

#### NOTES:

1. All values are for single anchors with no edge distance or spacing reduction and assume supplementary reinforcement condition B. Shear values exclude consideration of the concrete breakout failure mode.
2. Anchorage must be designed in accordance with ACI 318-05 Appendix D.
3. Allowable loads are for the attachment of non-structural components.
4. Allowable loads are based on 100% seismic loading in seismic design categories C-F.

REF. DWG. S-106